



**NOTES:**

1. Valves shall be set so that operating shaft is plumb.
2. Three inch riser sections shall be used when the valve box is to be placed in an existing or proposed asphalt roadway.

**NOTE 1: THIS DETAIL IS VALID ONLY WHEN USED AS PRESENTED HERE, WITHOUT CHANGES, AND IN CONJUNCTION WITH ANY GENERAL NOTES AND/OR OTHER DETAILS WHICH MAY APPLY. ANY CHANGES TO THIS DETAIL SHALL FIRST BE SUBMITTED TO AND APPROVED BY THE CITY ENGINEER.**

**NOTE 2: BEFORE ANY EXCAVATING, CALL THE FOLLOWING NUMBERS AT LEAST 48 HOURS IN ADVANCE: O.U.P.S. @ (800) 382-2784 AND O.A.G.P.U.P.S. @ (800) 925-0888.**

**City of Wooster : Division of Engineering**

538 N. Market Street Wooster, Ohio 44691

Phone: (330) 263-5234

Fax: (330) 263-5247

Joel Montgomery, P.E.  
City Engineer

NO.	DATE	REVISION			
1	7/18/01	ADDED VALVE MODEL NO.			
2	10/03/01	REV. VALVE MODEL NO.			
3	9/30/08	ADDED REFERENCE NOTE			

**VALVE SETTING  
DETAIL**

CAD FILE:  
ENGINEERING STANDARDS\WT-1.DWG

DRAWN BY: AJM	APPROV BY: EPO	ISSUE DATE: 11/08/00	SCALE: NONE
------------------	-------------------	-------------------------	----------------

SHEET:

**WT-8.0**